

**REGARDING SAFE DRINKING WATER AND SANITARY  
CONDITION**

**Certificate**

No. 61

DATE 27/04/2026

It is certified that an inspection team headed by— *Mr. Jai Kishan Kumar*  
(Assistant Chemist) from *P. H. Division Bhagalpur East, Bhagalpur*  
inspected the *Propel International School NH-80 Pannuchak, Ghogha,*  
*Bhagalpur Bihar* on *21.04.2026* and found the *Propel International*  
*School NH-80 Pannuchak, Ghogha, Bhagalpur Bihar* has safe drinking water  
facilities for the students and members of staff institution and is maintaining the hygienic  
sanitation condition in the school campus as per the norms prescribed by the  
*Central/State/U.T Govt.*

The above valid for a period of- *One Year (27.04.2026 to 26.04.2027)*.

Signature With Seal:-

Name

*Sanjay Kr Paswan*

Designation

*Assistant Research Officer*

To,

*Propel International School*  
*NH-80 Pannuchak,*  
*Ghogha, Bhagalpur*  
*Bihar-813205*



Government Of Bihar

# Regional Water Testing Laboratory

Public Health Engineering Department,  
Bhagalpur

Ref.No. EE-1337 dt-17.04.2026

Name of School :-Propel International School

Sample Collected By- Lab Staff

Date of Sampling - 21.04.2026

Source of Sample - R.O Water

## PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

S.No.	Location					Physico - Chemical and Bacteriological Parameters															Remarks
	Block	Panchayet	Village	Habitation	Name	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO <sub>3</sub>	SO <sub>4</sub>	F	As	T-Coli	
1	Propel International School NH-80,Pannuchak,Ghogha,Bhagalpur, Bihar-813205					7.18	0.49	171.2	85.6	43.9	17.4	5.84	24.2	35.2	0.16	2.75	5.8	0.11	NT	Negative	
	Desirable Limit*					6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45.0	200	1.0	0.01	-	
	Permissible Limit* in absence of alternate source					NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	**	

Note:- Not Tested

Memo No.... RL-61

Date .... 27/04/2026

Copy Forwarded To :1. Executive Engineer, P.H.Division Bhagalpur East, for kind information and necessary action.

*Lumax*  
27/04/26  
Lab Incharge(A.R.O)